



BRAILSFORD & DUNLAVEY

Facility Planners • Program Managers

Catalysts for Building Community



2010 NATIONAL CHARTER SCHOOLS CONFERENCE

A Beginner's Guide to Energy Modeling

Presentation Overview

I. Introduction to Energy Modeling

What, Why, and How?

II. Energy Model Sample Scenario

Anacostia High School Modernization Project

III. Q&A

Introduction to Energy Modeling

What is energy modeling?

A computer program that predicts building energy use based upon the materials and systems that are to be included with construction.

Why is energy modeling used?

- Meeting project sustainability goals
- Capital cost/benefit analysis
- Lifecycle cost analysis

How is energy modeling best used?

- In an integrated fashion throughout the design process

Energy Model Sample Scenario

Anacostia High School Modernization Project

- Value Engineering Exercise
- Question: should we accept \$88,000 add-alternate for high-efficiency chiller?
- Data shows additional 2% annual energy savings
- Client priority is LEED Gold, add-alternate accepted
- Sample model

Energy Cost Budget / PRM Summary

By Allen & Shariff Corporation

Project Name: Anacostia Senior High School	Date: June 09, 2010
City: Washington DC	Weather Data: Washington, D.C.

Note: The percentage displayed for the "Proposed/ Base %" column of the base case is actually the percentage of the total energy consumption.

* Denotes the base alternative for the ECB study.

		* Alt-1 WSC W/ VFD			Alt-2 Baseline			Alt-3 WMC			Alt-4 Existing Chillers		
		Energy 10 ⁶ Btu/yr	Proposed / Base %	Peak kBtuh	Energy 10 ⁶ Btu/yr	Proposed / Base %	Peak kBtuh	Energy 10 ⁶ Btu/yr	Proposed / Base %	Peak kBtuh	Energy 10 ⁶ Btu/yr	Proposed / Base %	Peak kBtuh
Lighting - Conditioned	Electricity	1,192.7	12	563	1,230.2	103	581	1,192.7	100	563	1,192.7	100	563
Space Heating	Electricity	134.9	1	17	66.7	49	11	134.9	100	17	135.0	100	17
	Gas	4,623.4	47	3,803	6,471.8	140	12,400	4,623.4	100	3,803	4,624.5	100	3,806
Space Cooling	Electricity	471.2	5	989	952.3	202	1,643	370.1	79	950	535.0	114	1,260
Pumps	Electricity	312.6	3	176	2,381.5	762	417	311.0	100	176	1,093.7	350	297
Heat Rejection	Electricity	178.1	2	94	267.1	150	219	176.3	99	94	93.2	52	47
Fans - Conditioned	Electricity	987.9	10	1,088	274.7	28	225	987.9	100	1,088	989.0	100	1,091
Receptacles - Conditioned	Electricity	1,912.5	19	636	1,912.5	100	629	1,912.5	100	636	1,912.5	100	636
Stand-alone Base Utilities	Electricity	24.3	0	5	48.6	200	10	24.3	100	5	24.3	100	5
Total Building Consumption		9,837.6			13,605.4			9,733.0			10,599.9		

		* Alt-1 WSC W/ VFD			Alt-2 Baseline			Alt-3 WMC			Alt-4 Existing Chillers		
Total	Number of hours heating load not met	637			728			637			637		
	Number of hours cooling load not met	124			0			124			120		

		* Alt-1 WSC W/ VFD		Alt-2 Baseline		Alt-3 WMC		Alt-4 Existing Chillers	
		Energy 10 ⁶ Btu/yr	Cost/yr \$/yr	Energy 10 ⁶ Btu/yr	Cost/yr \$/yr	Energy 10 ⁶ Btu/yr	Cost/yr \$/yr	Energy 10 ⁶ Btu/yr	Cost/yr \$/yr
Electricity		5,214.2	294,358	7,133.6	373,148	5,109.6	289,134	5,975.4	332,260
Gas		4,623.4	76,286	6,471.8	106,785	4,623.4	76,286	4,624.5	76,304
Total		9,838	370,644	13,605	479,933	9,733	365,420	10,600	408,564

Questions?

Jay Brinson, LEED AP
Brailsford and Dunlavey
jbrinson@facilityplanners.com

Booth C10